

Tabelle1

Therme Viessmann Vitodens 200-W, Typ B2HB/B2KB mit Vitotronic 20C

Soll-Wert Tag 20 Grad

Außentemperatur zwischen 7 und 12 Grad

Neigung 1,7 – Niveau 4 k

Messung: 16.02.2021 – 17.02.21

Ab Nachtabenkung 10 Grad rauscht Therme ständig. Bei 6° kein Rauschen mehr.

Tag	Uhrzeit	Kesseltemp.	Flamme	° Bad	° Wohnz.	Ventil WZ	Ventil Bad
16.02.21	14:00	58°	x			4	5
	14:10	53°	-			4	5
	14:15	50°	-			4	5
	14:23	45°	-			4	5
	14:31	34°	Start			4	5
	14:32	40°	x			4	5
	14:35	50°	x			4	5
	14:43	53°	x			4	5
	14:55	53°	x			4	5
	15:15	53°	x			4	5
	15:30	53°	x			4	5
	15:40	54°	x	17,7	20,1	4	5
	15:49	55°	x			4	5
	15:55	57°	x			4	5
	16:07	49°	-			4	5
	16:17	45°	-			4	5
	16:22	49°	Start			4	5
	16:27	54°	x			4	5
	16:28	55°	x			4	5
	16:30	56°	x			4	5
	16:33	58°	x			4	5
	16:37	60°	x	17,8	20,1	4	5
						4	5
	16:56	38°	-			4	5
	16:56	54°	Start			4	5
	16:59	45°	x			4	5
	17:18	52°	x			4	5
	17:25	52°	x			4	5
	17:33	54°	x			4	5
	17:35	55°	x			4	5
	17:40	58°	x			4	5
	17:42	60°	x			4	5
	17:49	57°	-			4	5
	18:08	49°	-			4	5
	18:20	40°	-			4	5
	18:24	53°	Start			4	5
	18:25	45°	x			4	5
	18:36	52°	x			4	5
	18:46	52°	x	17,9	20,3	4	5
	18:51	52°	x			4	5
19:05	55°	x			4	5	
19:16	58°	x			4	5	
19:18	57°	-			4	5	

Tabelle1

19:31	51°	-	18,1	20,4	4	5
19:43	45°	-			4	5
19:50	40°	-			4	5
19:51	57°	Start			4	5
19:52	47°	x			4	5
19:55	52°	x			4	5
20:28	56°	x			4	5
20:35	59°	x			4	5
20:36	58°	-			4	5
20:44	52°	-			4	5

Abschaltbetrieb bis 8:00

17.02.21	08:12	25°	Start	16,3	16	5	5
	08:14	35°	x			5	5
	08:16	38°	x			5	5
	08:18	40°	x			5	5
	08:21	42°	x			5	5
	08:22	44°	x			5	5
	08:26	49°	x			5	5
	08:40	51°	x			5	5
	08:46	50°	x			5	5
	08:56	50°	x			5	5
	09:30	50°	x			5	5
	09:43	51°	x			5	5
	09:53	54°	x			5	5
	10:00	56°	x			5	5
	10:02	55°	-			5	5
	10:19	36°	-			5	5
	10:20	51°	Start			5	5
	10:21	42°	x			5	5
	10:39	50°	x	16,9	19,5	5	5
	10:41	49°	x			5	5
	11:22	50°	x			5	5
	11:38	53°	x			5	5
	11:43	55°	x	17,2	20,3	5	5
	11:45	52°	-			5	5
	11:51	41°	-			5	5
	11:59	42°	Start			5	5
	12:00	45°	x			5	5
	12:09	49°	x			5	5
	12:34	48°	x	17,3	20,5	5	5
	12:52	50°	x	17,3	20,7	5	5
	13:06	53°	x	17,4	20,9	4	5
	13:10	52°	-			4	5
	13:24	52°	-			4	5
	13:35	48°	-			4	5
	14:04	39°	-			4	5
	14:05	54°	Start			4	5
	14:06	45°	x			4	5
	14:19	54°	x			4	5
	14:22	53°	-	17,6	20,8	4	5
	14:36	38°	-			4	5

Tabelle1

14:38	54°	-			4	5
14:54	48°	-			4	5
15:14	54°	Start			4	5
15:15	53°	x			4	5
15:36	47°	-			4	5
15:51	43°	-	17,8	20,6	4	5
16:04		Start			4	5

Tabelle1

), Typ HO1B